

REROOF CHECKLIST AND INSPECTION POLICY

CONTRACTOR TO VERIFY

- Roof framing is adequate and properly braced.
- Framing and sheathing in good condition, repaired or replaced as necessary.
- Appliance flues are connected and supported with minimum clearance to wood. (6" to single wall flue pipe, 1" to double wall flue pipe)

REQUIRED INSPECTIONS (PROVIDE LADDER)

- Sheathing Inspection:** Sheathing completed 100%. Flues installed and secured with proper clearance to combustibles (single wall 6" and double wall 1").
- Final Inspection**

THESE ADDITIONAL INSPECTIONS ARE REQUIRED (PROVIDE LADDER)

- Pre-Inspection of overlays
- Tear off Inspection for built-up roofs
- Repairs of dry rot
- Structural modifications or repairs
- Inspections required by product listing (*i.e. in progress inspection for shake to tile*)

INSPECTION INFORMATION

- Call the inspection line (916) 625-5136 prior to 6 a.m. for a same day inspection.
- On the day of your scheduled inspection, you may call (916) 625-5120 between 8 a.m. and 9 a.m. to talk to the inspector for a specific time request.
- Re-inspection fees may be issued when inspections are not ready.

All work subject to field inspection.