

**CALGREEN NON-RESIDENTIAL CHECKLIST  
MANDATORY MEASURES**

**PURPOSE:**

The non-residential provisions of the 2016 CalGreen Code outline planning, design and development methods that include environmentally responsible site selection, building design, building siting and development to protect, restore and enhance the environmental quality of the site and respect the integrity of adjacent properties; establishes the means of conserving water used indoors, outdoors and in wastewater conveyance; outlines means of achieving material conservation and resource efficiency; and outlines means of reducing the quantity of air contaminants.

Project Name: \_\_\_\_\_

Project Address: \_\_\_\_\_

Project Description: \_\_\_\_\_

**Instructions:**

1. The Owner or the Owner’s agent shall employ a licensed professional experienced with the 2016 California Green Building Standards Codes to verify and assure that all required work described herein is properly planned and implemented in the project.
2. The licensed professional, in collaboration with the owner and the design professional shall initial **Column 2** of this checklist, sign and date **Section 1 - Design Verification** at the end of this checklist and have the checklist printed on the approved plans for the project.
3. Prior to final inspection by the Building Department, the licensed professional shall complete **Column 3** and sign and date **Section 2 - Implementation Verification** at the end of this checklist and submit the completed form to the Building Inspector.

<b>MANDATORY FEATURE OR MEASURE</b>	<b>Column 2</b>	<b>Column 3</b>
	<b>Project Requirements</b>	<b>Verification</b>
<b>CHAPTER 5 – NONRESIDENTIAL MANDATORY MEASURES</b>		
<b>General Requirements</b>		
The project meets all the requirements of Divisions 5.101 through 5.508.	<input type="checkbox"/>	<input type="checkbox"/>
<b>Division 5.1 PLANNING AND DESIGN</b>		
<b>Planning and Design - Site Development</b>		
<b>5.106.1 Storm water pollution prevention.</b> For projects of one acre or less, develop a Storm Water Pollution Prevention Plan (SWPPP) that has been designed, specific to its site, conforming to the State Storm water NPDES Construction Permit or local ordinance, whichever is stricter, as is required for projects over one acre. The plan should cover prevention of soil loss by storm water run-off and/or wind erosion, of sedimentation and/or of dust/particulate matter air pollution.	<input type="checkbox"/>	<input type="checkbox"/>



## Division 5.2 ENERGY EFFICIENCY

### Performance Requirements

**5.201.1 Scope.** The California Energy Commission will continue to adopt mandatory building standards.



## Division 5.3 WATER EFFICIENCY AND CONSERVATION

### Indoor Water Use

**5.303.1 Meters.** Separate meters shall be installed for the uses described in Sections 503.1.1 and 503.1.2.

**5.303.1.1 New building or additions in excess of 50,000 square feet.** Separate submeters shall be installed as follows:

1. For each individual leased, rented or other tenant space within the building projected to consume more than 100 gal/day.
2. Where separate submeters are unfeasible, for water supplied to the following systems:
  - a. Makeup water for cooling towers where flow through is greater than 500 gpm.
  - b. Makeup water for evaporative coolers greater than 6 gpm.
  - c. Steam and hot-water boilers with energy input > 500,000 Btu/h.



**5.303.1.2 Excess consumption.** A separate submeter shall be provided for any tenant within a new building or within an addition that is projected to consume > 1,000 gal/day.



**5.303.3 Water conserving plumbing fixtures and fittings.** Plumbing fixtures (water closets and urinals) and fittings (faucets and showerheads) shall comply with the following:

**5.303.3.1. Water closets.** The effective flush volume of all water closets shall not exceed 1.28 gallons per flush. Tank-type water closets shall be certified to the performance criteria of the U.S. EPA WaterSense Specification for tank-type toilets.



**5.303.3.2 Urinals.**

**5.303.3.2.1 Wall-mounted urinals.** The effective flush volume of wall-mounted urinals shall not exceed 0.125 gallons per flush.



**5.303.3.2.2 Floor-mounted urinals.** The effective flush volume of floor-mounted or other urinal shall not exceed .05 gallons per flush.



**5.303.3.3 Showerheads.**

**5.303.3.3.1 Single showerhead.** Showerheads shall have a maximum flow rate of not more than 2.0 gallons per minute at 80 psi. Showerheads shall be certified to the performance criteria of the U.S. EPA WaterSense Specification for showerheads.



**5.303.3.3.2 Multiple showerheads serving one shower.** When a shower is served by more than one showerhead, the combined flow rate of all showerheads and/or other shower outlets controlled by a single valve shall not exceed 2.0 gallons per minute at 80 psi, or the shower shall be designed to allow only one shower outlet to be in operation at a time.











<p><b>5.504.4 Finish material pollutant control.</b> Finish materials shall comply with Sections 5.504.4.1 through 5.504.4.6.</p>		
<p><b>5.504.4.1 Adhesives, sealants, caulks.</b> Adhesives and sealants used on the project shall meet the requirements of the following standards.</p>		
<p>1. Adhesives, adhesive bonding primers, adhesive primers, sealants, sealant primers and caulks shall comply with local or regional air pollution control or air quality management district rules where applicable or SCAQMD Rule 1168 VOC limits, as shown in Tables 5.504.4.1 and 5.504.4.2.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>2. Aerosol adhesives and smaller unit sizes of adhesives and sealant or caulking compounds (in units of product, less packaging, which do not weigh more than one pound and do not consist of more than 16 fluid ounces) shall comply with statewide VOC standards and other requirements, including prohibitions on use of certain toxic compounds, of <i>California Code of Regulations</i>, Title 17, commencing with Section 94507.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p><b>5.504.4.3 Paints and coatings.</b> Architectural paints and coatings shall comply with Table 5.504.4.3 unless more stringent local limits apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p><b>5.504.4.3.1 Aerosol paints and coatings.</b> Aerosol paints and coatings shall meet the Product-Weighted MIR Limits for ROC in Section 94522(a)(3) and other requirements, including prohibitions on use of certain toxic compounds and ozone depleting substances (CCR, Title 17, Section 94520 et seq).</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p><b>5.504.4.3.2 Verification.</b> Verification of compliance with this section shall be provided at the request of the enforcing agency.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p><b>5.504.4.4 Carpet systems.</b> All carpet installed in the building interior shall meet the testing and product requirements of at least one of the standards listed in Section 5.504.4.4.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p><b>5.504.4.4.1 Carpet cushion.</b> All carpet cushion installed in the building interior shall meet the requirements of the Carpet and Rug Institute Green Label program.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p><b>5.504.4.4.2 Carpet adhesive.</b> All carpet adhesive shall meet the requirements of Table 5.504.4.1.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p><b>5.504.4.5 Composite wood products.</b> Hardwood plywood, particleboard and medium density fiberboard composite wood products used on the interior or exterior of the building shall meet the requirements for formaldehyde as specified in Table 5.504.4.5.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p><b>5.504.4.5.3 Documentation.</b> Verification of compliance with this section shall be provided as requested by the enforcing agency. Documentation shall include at least one of the following standards listed in Section 5.504.5.3.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p><b>5.504.4.6 Resilient flooring systems.</b> For 80 percent of floor area receiving resilient flooring, installed resilient flooring shall meet at least one of the following standards listed in Section 5.504.4.6.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p><b>5.504.5.3 Filters.</b> In mechanically ventilated buildings, provide regularly occupied areas of the building with air filtration media for outside and return air prior to occupancy that provides at least a MERV of 8.</p>	<input type="checkbox"/>	<input type="checkbox"/>







<p><b>5.508.2.2.2 Access valve.</b> Only Schrader access valves with a brass or steel body are permitted for use.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p><b>5.508.2.2.2.1 Valves caps.</b> For system with a refrigerant charge of 5 pounds or more, valve caps shall be brass or steel and not plastic.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p><b>5.508.2.2.2.2 Seal caps.</b> If designed for it, the cap shall have a neoprene O-ring in place.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p><b>5.508.2.2.2.2.1 Chain tethers.</b> Chain tethers to fit over the stem are required for valves designed to have seal caps.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p><b>5.508.2.3 Refrigerated service cases.</b> Refrigerated service cases holding food products containing vinegar and salt shall have evaporator coils of corrosion-resistant material, such as stainless steel; or be coated to prevent corrosion from these substances.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p><b>5.508.2.3.1 Coil coating.</b> Consideration shall be given to the heat transfer efficiency of coil coating to maximize energy efficiency.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p><b>5.508.2.4 Refrigerated receivers.</b> Refrigerant receivers with capacities greater than 200 pounds shall be fitted with a device that indicates the level of refrigerant in the receiver.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p><b>5.508.2.5. Pressure testing.</b> The system shall be pressure tested during installation prior to evacuation and charging.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p><b>5.508.2.5.1 Minimum pressure.</b> The system shall be charged with regulated dry nitrogen and appropriate tracer gas to bring system pressure up to 300 psig minimum.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p><b>5.508.2.5.2 Leaks.</b> Check the system for leaks, repair any leaks, and retest for pressure using the same gauge.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p><b>5.508.2.5.3 Allowable pressure change.</b> The system shall stand, unaltered, for 24 hours with no more than a +/- one pound pressure change from 300 psig, measured with the same gauge.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p><b>5.508.2.6 Evacuation.</b> The system shall be evacuated after pressure testing and prior to charging.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p><b>5.508.2.6.1 First vacuum.</b> Pull a system vacuum down to at least 1000 microns (+/- 50 microns), and hold for 30 minutes.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p><b>5.508.2.6.2 Second vacuum.</b> Pull second system vacuum to a minimum of 500 microns and hold for 30 minutes.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p><b>5.508.2.6.3 Third vacuum.</b> Pull a third vacuum down to a minimum of 300 microns, and hold for 24 hours with a maximum drift of 100 microns over a 24-hour period.</p>	<input type="checkbox"/>	<input type="checkbox"/>

# CALGREEN SIGNATURE DECLARATIONS

Project Name: \_\_\_\_\_  
Project Address: \_\_\_\_\_  
Project Description: \_\_\_\_\_

## SECTION 1 – DESIGN VERIFICATION

Complete all lines of Section 1 – “Design Verification” and submit the completed checklist (Columns 1 and 2) with the plans and building permit application to the Building Department.

The owner and design professional responsible for compliance with CalGreen Standards have revised the plans and certify that the items checked above are hereby incorporated into the project plans and will be implemented into the project in accordance with the requirements set forth in the 2016 California Green Building Standards Code as adopted by the City of Rocklin.

Owner's Signature	Date
Owner's Name (Please Print)	
Design Professional's Signature	Date
Design Professional's Name (Please Print)	
Signature of License Professional responsible for CalGreen compliance	Date
Name of License Professional responsible for CalGreen compliance (Please Print)	Phone
Email Address for License Professional responsible for CalGreen compliance	

## SECTION 2 – IMPLEMENTATION VERIFICATION

Complete, sign and submit the completed checklist, including column 3, together with all original signatures on Section 2 to the Building Department prior to Building Department final inspection.

I have inspected the work and have received sufficient documentation to verify and certify that the project identified above was constructed in accordance with this Green Building Checklist and in accordance with the requirements of the 2016 California Green Building Standards Code as adopted by the City of Rocklin.

Signature of License Professional responsible for CalGreen compliance	Date
Name of License Professional responsible for CalGreen compliance (Please Print)	Phone
Email Address for License Professional responsible for CalGreen compliance	