

**CALGREEN NON-RESIDENTIAL CHECKLIST
MANDATORY MEASURES**

PURPOSE:

The non-residential provisions of the 2019 CalGreen Code outline planning, design and development methods that include environmentally responsible site selection, building design, building siting and development to protect, restore and enhance the environmental quality of the site and respect the integrity of adjacent properties; establishes the means of conserving water used indoors, outdoors and in wastewater conveyance; outlines means of achieving material conservation and resource efficiency; and outlines means of reducing the quantity of air contaminants.

Project Name: _____

Project Address: _____

Project Description: _____

Instructions:

1. The Owner or the Owner’s agent shall employ a licensed professional experienced with the 2019 California Green Building Standards Codes to verify and assure that all required work described herein is properly planned and implemented in the project.
2. The licensed professional, in collaboration with the owner and the design professional shall initial **Column 2** of this checklist, sign and date **Section 1 - Design Verification** at the end of this checklist and have the checklist printed on the approved plans for the project.
3. Prior to final inspection by the Building Department, the licensed professional shall complete **Column 3** and sign and date **Section 2 - Implementation Verification** at the end of this checklist and submit the completed form to the Building Inspector.

MANDATORY FEATURE OR MEASURE	Column 2	Column 3
	Project Requirements	Verification
CHAPTER 5 – NONRESIDENTIAL MANDATORY MEASURES		
General Requirements		
The project meets all the requirements of Divisions 5.101 through 5.508.	<input type="checkbox"/>	<input type="checkbox"/>
Division 5.1 PLANNING AND DESIGN		
Planning and Design - Site Development		
5.106.1 Storm water pollution prevention. For projects of one acre or less, develop a Storm Water Pollution Prevention Plan (SWPPP) that has been designed, specific to its site, conforming to the State Storm water NPDES Construction Permit or local ordinance, whichever is stricter, as is required for projects over one acre. The plan should cover prevention of soil loss by storm water run-off and/or wind erosion, of sedimentation and/or of dust/particulate matter air pollution.	<input type="checkbox"/>	<input type="checkbox"/>

<p>1. Adhesives, adhesive bonding primers, adhesive primers, sealants, sealant primers and caulks shall comply with local or regional air pollution control or air quality management district rules where applicable or SCAQMD Rule 1168 VOC limits, as shown in Tables 5.504.4.1 and 5.504.4.2.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>2. Aerosol adhesives and smaller unit sizes of adhesives and sealant or caulking compounds (in units of product, less packaging, which do not weigh more than one pound and do not consist of more than 16 fluid ounces) shall comply with statewide VOC standards and other requirements, including prohibitions on use of certain toxic compounds, of <i>California Code of Regulations</i>, Title 17, commencing with Section 94507.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>5.504.4.3 Paints and coatings. Architectural paints and coatings shall comply with Table 5.504.4.3 unless more stringent local limits apply.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>5.504.4.3.1 Aerosol paints and coatings. Aerosol paints and coatings shall meet the Product-Weighted MIR Limits for ROC in Section 94522(a)(3) and other requirements, including prohibitions on use of certain toxic compounds and ozone depleting substances (CCR, Title 17, Section 94520 et seq).</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>5.504.4.3.2 Verification. Verification of compliance with this section shall be provided at the request of the enforcing agency.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>5.504.4.4 Carpet systems. All carpet installed in the building interior shall meet the testing and product requirements of at least one of the standards listed in Section 5.504.4.4.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>5.504.4.4.1 Carpet cushion. All carpet cushion installed in the building interior shall meet the requirements of the Carpet and Rug Institute Green Label program.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>5.504.4.4.2 Carpet adhesive. All carpet adhesive shall meet the requirements of Table 5.504.4.1.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>5.504.4.5 Composite wood products. Hardwood plywood, particleboard and medium density fiberboard composite wood products used on the interior or exterior of the building shall meet the requirements for formaldehyde as specified in Table 5.504.4.5.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>5.504.4.5.3 Documentation. Verification of compliance with this section shall be provided as requested by the enforcing agency. Documentation shall include at least one of the following standards listed in Section 5.504.5.3.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>5.504.4.6 Resilient flooring systems. For 80 percent of floor area receiving resilient flooring, installed resilient flooring shall meet at least one of the following standards listed in Section 5.504.4.6.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>5.504.5.3 Filters. In mechanically ventilated buildings, provide regularly occupied areas of the building with air filtration media for outside and return air prior to occupancy that provides at least a MERV of 13.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>5.504.7 Environmental tobacco smoke (ETS) control. Prohibit smoking within 25 feet of building entries, outdoor air intakes and operable windows where outdoor areas are provided for smoking and in buildings; or as enforced by ordinances, regulations or policies of any city, county, city and county, California Community College, campus of the California State University or campus of the University of California, whichever are more stringent.</p>	<input type="checkbox"/>	<input type="checkbox"/>

Indoor Moisture and Radon Control		
5.505.1 Indoor moisture control. Buildings shall meet or exceed the provisions of <i>California Building Code</i> , CCR, Title 24, Part 2, Sections 1203 and Chapter 14.1.	<input type="checkbox"/>	<input type="checkbox"/>
Air Quality and Exhaust		
5.506.1 Outside air delivery. For mechanically or naturally ventilated spaces in buildings, meet the minimum requirements of Section 120.1 of the <i>California Energy Code</i> , CCR, Title 24, Part 6 and Chapter 4 of CCR, Title 8 or the applicable local code, whichever is more stringent. ¹	<input type="checkbox"/>	<input type="checkbox"/>
5.506.2 Carbon dioxide (CO2) monitoring. For buildings equipped with demand control ventilation, CO2 sensors and ventilation controls shall be specified and installed in accordance with the requirements of the latest edition of the <i>California Energy Code</i> , CCR, Title 24, Part 6, Section 120.1(c)(4). ¹	<input type="checkbox"/>	<input type="checkbox"/>
Environmental Comfort		
5.507.4 Acoustical control. Employ building assemblies and components with STC values determined in accordance with ASTM E 90 and ASTM E 413.	<input type="checkbox"/>	<input type="checkbox"/>
5.507.4.1. Exterior noise transmission, prescriptive method. Wall and floor-ceiling assemblies exposed to the noise source making up the building envelope shall have exterior wall and roof ceiling assemblies meeting a composite STC rating of at least 50 or a composite OITC rating of no less than 40 with exterior windows of a minimum STC of 40 or OITC of 30 in the locations described in Items 1 and 2. Also applies to addition envelope or altered envelope.	<input type="checkbox"/>	<input type="checkbox"/>
5.507.4.1.1 Noise exposure where noise contours are not readily available. Buildings exposed to a noise level of 65 dB Leq-1Hr during any hour of operation shall have exterior wall and roof-ceiling assemblies exposed to the noise source meeting a composite STC rating of at least 45 (or OITC 35), with exterior windows of a minimum STC of 40 (or OITC 30). Also applies to addition or alteration exterior wall.	<input type="checkbox"/>	<input type="checkbox"/>
5.507.4.2 Performance method. For buildings located as defined in Sections A5.507.4.1 or A5.507.4.1.1, wall and roof-ceiling assemblies making up the building envelope shall be constructed to provide an interior noise environment attributable to exterior sources that does not exceed an hourly equivalent noise level (Leq-1Hr) of 50 DBA in occupied areas during any hour of operation. Also applies to addition envelope or altered envelope.	<input type="checkbox"/>	<input type="checkbox"/>
5.507.4.2.1 Site features. Exterior features such as sound walls or earth berms may be utilized as appropriate to the project to mitigate sound migration to the interior. Also applies to addition envelope or altered envelope.	<input type="checkbox"/>	<input type="checkbox"/>
5.507.4.2.2 Documentation of compliance. An acoustical analysis documenting complying interior sound levels shall be prepared by personnel approved by the architect or engineer of record.	<input type="checkbox"/>	<input type="checkbox"/>
5.507.4.2 Interior sound. Wall and floor-ceiling assemblies separating tenant spaces and tenant spaces and public places shall have an STC of at least 40.	<input type="checkbox"/>	<input type="checkbox"/>

<p>5.508.2.2.2.1 Valves caps. For system with a refrigerant charge of 5 pounds or more, valve caps shall be brass or steel and not plastic.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>5.508.2.2.2.2 Seal caps. If designed for it, the cap shall have a neoprene O-ring in place.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>5.508.2.2.2.1 Chain tethers. Chain tethers to fit over the stem are required for valves designed to have seal caps.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>5.508.2.3 Refrigerated service cases. Refrigerated service cases holding food products containing vinegar and salt shall have evaporator coils of corrosion-resistant material, such as stainless steel; or be coated to prevent corrosion from these substances.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>5.508.2.3.1 Coil coating. Consideration shall be given to the heat transfer efficiency of coil coating to maximize energy efficiency.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>5.508.2.4 Refrigerated receivers. Refrigerant receivers with capacities greater than 200 pounds shall be fitted with a device that indicates the level of refrigerant in the receiver.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>5.508.2.5. Pressure testing. The system shall be pressure tested during installation prior to evacuation and charging.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>5.508.2.5.1 Minimum pressure. The system shall be charged with regulated dry nitrogen and appropriate tracer gas to bring system pressure up to 300 psig minimum.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>5.508.2.5.2 Leaks. Check the system for leaks, repair any leaks, and retest for pressure using the same gauge.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>5.508.2.5.3 Allowable pressure change. The system shall stand, unaltered, for 24 hours with no more than a +/- one pound pressure change from 300 psig, measured with the same gauge.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>5.508.2.6 Evacuation. The system shall be evacuated after pressure testing and prior to charging.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>5.508.2.6.1 First vacuum. Pull a system vacuum down to at least 1000 microns (+/- 50 microns), and hold for 30 minutes.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>5.508.2.6.2 Second vacuum. Pull second system vacuum to a minimum of 500 microns and hold for 30 minutes.</p>	<input type="checkbox"/>	<input type="checkbox"/>
<p>5.508.2.6.3 Third vacuum. Pull a third vacuum down to a minimum of 300 microns, and hold for 24 hours with a maximum drift of 100 microns over a 24-hour period.</p>	<input type="checkbox"/>	<input type="checkbox"/>

CALGREEN SIGNATURE DECLARATIONS

Project Name: _____
Project Address: _____
Project Description: _____

SECTION 1 – DESIGN VERIFICATION

Complete all lines of Section 1 – “Design Verification” and submit the completed checklist (Columns 1 and 2) with the plans and building permit application to the Building Department.

The owner, design professional and contractor responsible for compliance with CalGreen Standards have revised the plans and certify that the items checked above are hereby incorporated into the project plans and will be implemented into the project in accordance with the requirements set forth in the 2019 California Green Building Standards Code as adopted by the City of Rocklin.

Owner's Signature	Date
Owner's Name (Please Print)	
Design Professional's Signature	Date
Design Professional's Name (Please Print)	
Signature of License Contractor	Date
Name of License Contractor (Please Print)	Phone
Company	

SECTION 2 – IMPLEMENTATION VERIFICATION

Complete, sign and submit the completed checklist, including column 3, together with all original signatures on Section 2 to the Building Department prior to Building Department final inspection.

I have inspected the work and have received sufficient documentation to verify and certify that the project identified above was constructed in accordance with this Green Building Checklist and in accordance with the requirements of the 2019 California Green Building Standards Code as adopted by the City of Rocklin.

Signature of Design Professional or License Contractor	Date
Name of Design Professional or License Contractor responsible for CalGreen compliance (Please Print)	Phone
Company	