

REROOF CHECKLIST AND INSPECTION POLICY

CONTRACTOR TO VERIFY

- Roof framing is adequate and properly braced.
- Framing and sheathing in good condition, repaired or replaced as necessary.
- Appliance flues are connected and supported with minimum clearance to wood. (6" to single wall flue pipe, 1" to double wall flue pipe)

REQUIRED INSPECTIONS (PROVIDE LADDER)

- Sheathing Inspection** *Sheathing completed 100%. Flues installed and secured with proper clearance to combustibles (single wall 6" and double wall 1").*
- Final Inspection**

THESE ADDITIONAL INSPECTIONS ARE REQUIRED (PROVIDE LADDER)

- Pre-Inspection of overlays**
- Tear off Inspection for built-up roofs**
- Repairs of dry rot**
- Structural modifications or repairs**
- Inspections required by product listing (*i.e. in progress inspection for shake to tile*)**

Call 916.625.5136 to schedule inspections prior to 6:00 AM the day of the inspection. On the day of your scheduled inspection, you may call 916.625.5120 between 7:00 AM and 7:30 AM to talk to the inspector for a specific time request.

Re-inspection fees may be issued when inspections are not ready. Your cooperation is appreciated.